
	<p align="center">GUJARAT ENERGY TRANSMISSION CORPORATION LTD (Formerly known as G. E. Board) HEAD OFFICE: SARDAR PATEL VIDYUT BHAVAN RACE COURSE, VADODARA – 390 007 CIN: U40100GJ1999SGC36018 Phone No: (0265) 2310582-86, Direct:(0265) 2343245 Email: ceengg.getco@gebmail.com Web: www.getcogujarat.com</p>	
---	---	---

To,
M/s STELMEC Ltd,
Ahmedabad Sanand Road.
Near Ularia Bus – Stand,
Sanand, Ahmedabad,
Gujarat – 382 110

Sub: Drawing Approval of various 11 kV VCB Panels & 22 kV VCB Panels -Approval thereof.

Ref: 1)LOA No: ACE(P&C)//EE(Proc)/III/E-2946/11KV VCB /LOA/Stelmec/2750 Dtd. 20.03.24.

2)Your mail requesting for drawing approval vide mail dtd. 05.04.24.

Dear Sir,

With reference to above subject matter, drawing approval request for 11kV VCB Panel Board (02 Nos. of Incomer (1600A) + 06 Nos. of Feeder(1250A) + 01 No. of Bus-coupler(1600A)) received vide email under ref. 2. The drawing approval is accorded as under with following consideration.

The numerical protective relays shall be as quoted during bidding stage.

Relay	Make	Type
Non –Directional O/C & E/F relay	Ashida/Siemens	ADR241B/7SR10

Sr. No.	Description	Drawing No.	Rev. No. & Date	No. of Sheets- Approved with Comments - *
1	11 kV VCB Panel Board (02 Nos. of Incomer(1600A) + 06 Nos. of Feeder(1250A) + 01 No. of Bus-coupler (1600A) with Integrated Adapter Cubicle. (Panel Type- SIVP12 VC-32, VCB Type – VC-32, VI Make- Stelmec, (Type –SVI 1226-20)			
1.1	Cover Sheet	S73181739A	R1,09.04.24	01 *
1.2	List of Content	S73121739A	R1,09.04.24	01 *
1.3	Bill of Material	S73141739A	R1,09.04.24	15 *
1.4	GA drawings	S73101739A	R1,09.04.24	50 *
1.5	GA of VCB Trolley	S73101739DA	R1,09.04.24	06 *
1.6	VI Drawing, Photo & Datasheet	S73101739K	R1,09.04.24	02 *
1.7	GA Drawings for CT	S73101739JA	R1,09.04.24	03 *
1.8	Limit Switch arrangement for Pressure Relief Flap	S73101739EA	R1,09.04.24	05 *
1.9	Spout Drawings	S73101739FA	R1,09.04.24	11 *
1.10	GA Drawings for PT	S73101739GA	R1,09.04.24	08
1.11	Panel front door locking arrangement & IC drawings	S73101739HA	R1,09.04.24	06

File No: GETCO/DRA/e-file/447/2024/7393/Technical
Approved By: Additional Chief Engineer, Technical, GETCO
Open the document in Adobe Acrobat DC to verify the E-sign



1.12	Shutter Assembly drawings	S73101739IA	R1,09.04.24	06
1.13	Single Line Diagram	S73111739GA	R1,09.04.24	03
1.14	Schematic drawings for Incomer (with Siemens relay) with Siemens Relay	S73111739A	R1,09.04.24	14
1.15	Schematic drawings for Feeder (with Siemens Relay)	S73111739B	R1,09.04.24	10
1.16	Schematic drawings for Bus-coupler(with Siemens relay)	S73111739D	R1,09.04.24	13
1.17	Wiring block with Ashida relay for Incomer Panel	S73111739A	R1,09.04.24	1
1.18	Wiring block with Ashida relay for Feeder Panel	S73111739B	R1,09.04.24	1
1.19	Wiring block with Ashida relay for Bus-coupler Panel	S73111739D	R1,09.04.24	1
1.20	Inter-panel wiring	S73111739E	R1,09.04.24	05
1.21	Rating plate drawing	S73171739A	R1,09.04.24	03
1.22	Lifting drawing	S73171739X	R1,09.04.24	01

All the above approved drawings and this letter shall be made available to inspector as and when required.

Final As-built drawing after incorporating all above points shall be submitted prior to offering inspection.

Moreover, the following documents shall be submitted as confirmed vide your e-mail Dtd. 15.01.24 respectively during Bid-Evaluation Stage.

1. Type Test Report of Relays.

Also, following documents are pending.

1. Type test report of Auxiliary switch
2. MQP (as per new specs)

This approval, however, does not absolve you from the warranty/obligations of the workmanship or from rectifying the defects due to faulty design or use of incorrect materials.

This is without any prejudice to the terms and conditions of the order.

Thanking you,

Yours faithfully,

For, Gujarat Energy Transmission Corporation Ltd.

(R. K. Patel)

Additional Chief Engineer(Engg)

Copy to: - CE (P&C) GETCO, Corporate Office, Vadodara.

- for information pls

